



TECHNICAL INFORMATION

The following module is based on the specifications below:

Membrane Type	Composite Polyamide Membrane	Chlorine removal required
Nominal Size	2.5" x 21"	Tape wrap: Yellow
Productivity Rate	500 gpd ± 15% (78.8 lph)	@ 150 psi, 77°F, Potable Water
Minimum Rejection	95%	Typical 97% - 98%

T2521-500 ELP EXTRA LOW PRESSURE REPLACEMENT ELEMENT



A= 21"

B=2.5" nom.

C=0.75" o.d.

RECOMMENDED OPERATING PARAMETERS		
Pressure	2.1 to 10.3 bar	Overall performance improves with pressure
Pressure: Recommended Use	10.3 bar (150 psi)	
pH	4.0 to 11.0	2.5 during cleaning cycles is ok
Temperature	4 to 45 °C	Size element GPD for lowest water temperature during the year
Minimum Concentrate Flow	5 times Permeate Flow	Lower ratios increase the rate of fouling
Maximum Feed Concentration	750 ppm	
Maximum Feed Flow Turbidity	5 NTU	
Maximum Feed Silt Density	5 SDI	
Chlorine Tolerance	0	Total removal recommended. The membrane has approximately 1000 ppm-hr tolerance
Minimum TDS Rejection	95%	97 to 98% is typical on most city water